



Robert P. Astorino  
County Executive

Department of Environmental Facilities

Thomas J. Lauro, P.E.  
Commissioner

December 17, 2013

Mr. Rudolph C. Petrucelli, P.E.  
Petrucelli Engineering  
392 Columbus Avenue  
Valhalla, NY 10595

Re: Mamaroneck SSD and Mamaroneck Trunk Sewer System  
Harbor Mews Project  
208 West Boston Post Road  
Mamaroneck (V)


Dear Mr. Petrucelli:

Receipt of your December 11, 2013 letter to the Department requesting a statement of adequate capacity for the County's Sewerage Facilities to serve the above referenced project is acknowledged. Please be advised that Westchester County's Mamaroneck Wastewater Treatment Plant and Mamaroneck Trunk Sewer system will serve and have sufficient capacity to accommodate the proposed flow of 1,500 gallons per day to be generated by the above referenced project. Since it appears that the sewer connection from the property will discharge into the Village of Mamaroneck's sanitary sewer system prior to discharge into County owned facilities, you must contact the Village of Mamaroneck in order to obtain a statement of adequate capacity and condition of the Village's sanitary sewer system to accommodate the sewerage flows generated from the project.

However, we propose as we have done in other County sewer districts that the additional flow to the system is offset by reductions in inflow and infiltration (I&I). The removal for this project should be on a three for one ratio similar to the requirements by NYSDEC for sewer extension approvals in the New Rochelle sewer district. We feel this project warrants the same consideration. For units that are considered fair and affordable housing units, the removal ratio for those units can be reduced to a one to one ratio.

Please contact the undersigned at (914) 813-5419 if you need further information.

Very truly yours,



Marian Pompa, Jr., P.E.  
Associate Engineer

cc: Thomas Lauro, P.E., Commissioner  
Joseph Gibney, P.E., Director, Wastewater Treatment  
Michael Facelle, P.E., Director of Maintenance  
file

Division of Solid Waste  
Wastewater Treatment  
Water Agency

270 North Avenue  
New Rochelle, New York 10801

Telephone: (914) 813-5400

Fax: (914) 813-5460

Website: westchestergov.com

